



CITY OF FORT WALTON BEACH



December 11, 2013

Re: ITB 14-002: Construction of Two (2) Dumpster Pads & Enclosures

ADDENDUM NUMBER 1

This addendum is issued to make the following clarifications (Questions & Answers):

Q. Provide some detail or specification for the steel gate called for on both enclosures.

A. The City would prefer an economical, steel painted gate. You may also quote alternatives of higher-quality, if desired.

Q. Will the metal roof be a standard color?

A. The color will be owner-determined, but it will be a standard manufacturer's color.

Q. Regarding the dumpster pad without a roof, can fiber-reinforced concrete be used in lieu of 6x6 inch wire mesh for the new slab?

A. No. 6x6 inch wire mesh is required. Fiber-reinforced concrete product may be quoted in conjunction with the required mesh.

Issued by: Paul L. Eubanks, Purchasing Agent

ACKNOWLEDGEMENT:

I hereby certify that I have received Addendum #1 for ITB 14-002.

Signature

Date Signed

Name & Title (type or print)

Company

THIS ACKNOWLEDGMENT MUST BE RETURNED WITH THE PROPOSAL PACKAGE.